

**Drinking Water Quality and Compliance
Town Short Form – A Template for Annual Notice to Consumers**

Introduction

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the **Town of St Brieux and Lakeview Developments** water quality and sample submission compliance record for the **January 1, 2022 to December 31, 2022** time period. This report was completed November 27, 2023. Readers should refer to Water Security Agency's Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502 for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: http://www.hc-sc.gc.ca/ewh-smtpubs/water-eau/index_e.html.

Water Quality Standards

Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Lakeview Developments				
Total Coliform	0 Organisms/100 mL	12	12	0%
Background Bacteria	Less than 200/100 mL	12	12	0%
Town of St Brieux				
Total Coliform	0 Organisms/100 mL	52	50	0%
Background Bacteria	Less than 200/100 mL	52	50	0%

** Please note one test froze and one test was not delivered by Canada Post on time.**

Water Disinfection –

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Lakeview Developments						
Chlorine Residual	0.1 mg/L free OR 0.4 mg/L total	0.61 – 2.05	0.39-1.49	12	12	100%
Town of St Brieux						
Chlorine Residual	0.1 mg/L free OR 0.4 mg/L total	0.53-2.24	0.04-1.52	52	50	100%

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records

Parameter	Test Level Limit (mg/L)	# Tests Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	0.02-2.88	365	0

A minimum of 0.4 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	1.00	.08-.97	0	0.97	365	365

More information on water quality and sample submission performance may be obtained from:

Town of St Brieux Box 249 St Brieux, SK. S0K 3V0
Telephone Number 306-275-2257 Facsimile Number 306-275-4949
E-mail address brieux@sasktel.net

